



- NOTES:
1. ADDITIONAL POST LENGTH WILL BE REQUIRED WHEN P.U.D. SERVICE CONDUCTOR CROSSES ROADS OR DRIVEWAY.

FIGURE 2-1

	100-200 AMP METER BASE TEMPORARY OVERHEAD SERVICE	
	DATE 11-18-03 DWN. BY <i>Silvany Lima</i> DWG NAME FIGURE2-1	TILLAMOOK P.U.D. OREGON 24 TILLAMOOK

**TILLAMOOK PEOPLE'S UTILITY DISTRICT
CONSTRUCTION GUIDELINES
TEMPORARY OVERHEAD SERVICE**

1. Customer is responsible for providing and installing a temporary post and meter base that will meet State and TPUD specifications as shown on the reverse.
2. Customer is responsible for obtaining a State electrical permit and a State inspection prior to the connection of electrical service. (State Electrical Inspector, 842-3440, located in Tillamook County Courthouse, Building Department).
3. If a service extension fee is required, the fee must be paid and line extension agreement signed prior to the installation of service.
4. Customer is responsible for filing an "Application for Service" card with the Engineering Department prior to scheduling the installation.
5. Location of the temporary must be approved by the Engineering Department.
6. Temporaries may not be placed on trees or TPUD poles.
7. Cost estimates are good for 180 days only.
8. Required easements, tree trimming permits, property descriptions and signatures are the responsibility of the customer.
9. Please refer to sketches on clearances.

These are only general requirements. Customer must meet or exceed NEC requirements. More specific requirements may be made on individual installations.