



NOTE:

1. Conduit cement: All weather quick-set cement (Carlson VC-998) or equivalent is required.
2. All conduits will penetrate 4" into vault, and will be grouted. No bell ends or couplers to be inside the vault.
3. T.P.U.D. does not assume ownership of vaults & conduits until T.P.U.D. facilities are installed.
4. Conduit entrance into vault will be 90° from vault face. See Options 1 & 2.
5. Conduit will be routed through inside knockouts only.

FIGURE 5-20

	REQUIREMENTS FOR CONDUIT ROUTING INTO VAULTS	
	DATE 11-18-03 DWN. BY <i>Tiffany Lima</i> DWG. NAME FIGURES-20	TILLAMOOK P.U.D. OREGON 24 TILLAMOOK